

DEPARTMENT OF PUBLIC WORKS

P. O. Box 4186, San Rafael, CA 94913-4186 • 415/499-6528 • FAX 415/499-3799 • TTY 415/473-3232

COUNTY OF MARIN
www.co.marin.ca.us/pw

ADMINISTRATION
499-6528

ACCOUNTING
499-7877 • FAX 507-2899

AIRPORT
451-A AIRPORT ROAD
NOVATO, CA 94945
897-1754 • FAX 897-1264

BUILDING MAINTENANCE
499-6576 • FAX 499-3250

CAPITAL PROJECTS
499-7877 • FAX 499-3724

COMMUNICATION
MAINTENANCE
499-7313 • FAX 499-3738

DISABILITY ACCESS
499-6528
CALIFORNIA RELAY SERVICE 711

ENGINEERING & SURVEY
499-7877 • FAX 499-3724

FLOOD CONTROL DISTRICT
499-6528

COUNTY GARAGE
499-7380 • FAX 499-7190

LAND DEVELOPMENT
499-6549

PRINTING
499-6377 • FAX 499-6617

PURCHASING
499-6371

REAL ESTATE
499-6578 • FAX 473-2391

ROAD MAINTENANCE
499-7388 • FAX 499-3656

STORMWATER PROGRAM
499-6528

TRANSPORTATION
PLANNING & TRAFFIC
OPERATIONS
499-6528

WASTE MANAGEMENT
499-6647 • FAX 473-2391

ALL AREA CODES ARE 415

February 7, 2012

Board of Supervisors
Marin County Flood Control & Water Conservation District
3501 Civic Center Drive
San Rafael, CA 94903

SUBJECT: Notice of Completion
Cheda Creek Pump Station Repair, FCZ 1 (Novato)
Project No. LUFX-11

Dear Board Members:

RECOMMENDATIONS: (1) Authorize the President and Clerk to execute the attached Notice of Completion and direct the Clerk of the Board to record the document; and (2) Authorize the release of the retention 35 days following action by your Board in the amount of \$11,968.95 to Bartley Pump, Inc. of Santa Rosa.

SUMMARY: The Cheda Creek Pump Station is a critical flood protection facility located adjacent to CA-37 and Novato Creek. The pump station was over 40 years old and at the end of its serviceable life. The Cheda Creek Pump station provides drainage for runoff from the intersection of US-101 and CA-37 and communities upstream and also functions as a backup to the Lynwood Pump Station that provides drainage for much of Novato. This project replaced the pumps and retrofit key features in order to provide a reliable pumping system for the Cheda Creek watershed. In addition, a broken portion of the wall of the concrete wet well was reconstructed, the steel beams supporting the pumps were removed and reinstalled, and the deteriorated outfall pipe was replaced.

FISCAL IMPACT: The total construction cost was \$239,379. The contract will be paid from FCZ 1 Fund 23710 fund center 6210011000. There is no impact to the General Fund.

REVIEWED BY:	<input checked="" type="checkbox"/>	Department of Finance	<input type="checkbox"/>	N/A
	<input type="checkbox"/>	County Counsel	<input checked="" type="checkbox"/>	N/A
	<input type="checkbox"/>	Human Resources	<input checked="" type="checkbox"/>	N/A

Respectfully submitted,


Ernest Klock
Principal Civil Engineer

MERIT Doc. # 10024321

c: Tracy J. Clay



